

---

## CAN/ULC-S102 Surface Burning Characteristics of "Snaile Locker Metal Cabinet"

A Report To: **Snaile Inc.**  
1 Crescent Road, Suite 214  
Huntsville, ON, Canada  
P1H 1Z6

Phone: +1 705-242-4808

Attention: Patrick Armstrong  
E-mail: patrick.armstrong@snaile.com

Submitted by: Element Fire Testing

Report No. 20-002-509  
6 Pages

Date: November 16, 2020

**1.0 ACCREDITATION** To ISO/IEC 17025 for a defined Scope of Testing by the International Accreditation Service

## 2.0 SPECIFICATIONS OF ORDER

Determine Flame Spread Rating and Smoke Developed Classification based upon triplicate testing conducted in accordance with CAN/ULC-S102-2018, as per Snaile Inc. reference Purchase Order No. 1484 and Element Quotation No. 20-002-173095 dated May 25, 2020.

**3.0 SAMPLE IDENTIFICATION** (Element sample identification number 20-002-S0509)

Coating system described as, "1.2 mm steel with powder coat", and identified as:  
"Snaile Locker Metal Cabinet"

## 4.0 TEST PROCEDURE

The method, designated as CAN/ULC-S102-2018, "*Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies*", is designed to determine the relative surface burning characteristics of materials under specific test conditions. Results of less than three identical specimens are expressed in terms of Flame Spread Value (FSV) and Smoke Developed Value (SDV). Results of three or more replicate tests on identical samples produce average values expressed as Flame Spread Rating (FSR) and Smoke Developed Classification (SDC).

Although the procedure is applicable to materials, products and assemblies used in building construction for development of comparative surface spread of flame data, the test results may not reflect the relative surface burning characteristics of tested materials under all building fire conditions.

## 5.0 SAMPLE PREPARATION

Each test specimen consisted of a total of four prepared panel sections, each approximately 1.2 mm in thickness (including substrate) by 533 mm in width by 1829 mm in length. The sections were butted together to create the specimen length. Prior to testing, each specimen was conditioned to constant weight at a temperature of  $23 \pm 3^{\circ}\text{C}$  and a relative humidity of  $50 \pm 5\%$ . At the time of test initiation, the specimens were self-supporting.

Testing was performed on: Test #1: 2020-11-12 Test #2: 2020-11-12 Test #3: 2020-11-12

## 6.0 SUMMARY OF TEST PROCEDURE

The tunnel is preheated to  $85^{\circ}\text{C}$ , as measured by the backwall-embedded thermocouple located 7090 mm downstream of the burner ports, and allowed to cool to  $40^{\circ}\text{C}$ , as measured by the backwall-embedded thermocouple located 4000 mm from the burners. At this time the tunnel lid is raised and the test sample is placed along the ledges of the tunnel so as to form a continuous ceiling 7315 mm long, 305 mm above the floor. The lid is then lowered into place.

## 6.0 SUMMARY OF TEST PROCEDURE (continued)

Upon ignition of the gas burners, the flame spread distance is observed and recorded every second. Flame spread distance versus time is plotted. Calculations ignore all flame front recessions and the Flame Spread Values (FSV) are determined by calculating the total area under the curve for each test sample. If the total area under the curve (AT) is less than or equal to 29.7 m·min,  $FSV = 1.85 \cdot AT$ ; if greater,  $FSV = 1640 / (59.4 - AT)$ .

The Smoke Developed Value is determined by comparing the area under the obscuration curve for the test sample to that of inorganic reinforced cement board and red oak, established as 0 and 100, respectively. The Smoke Developed Value (SDV) is determined by dividing the total area under the obscuration curve by that of red oak and multiplying by 100.

## 7.0 TEST RESULTS

### SAMPLE: "Snaile Locker Metal Cabinet"

Test	Approx. Time to Ignition (s)	Maximum Flame Front Distance (m)	Time to Maximum Flame Front (s)	Maximum Air Temperature (°C)	Flame Spread Value (FSV)	Smoke Developed Value (SDV)
1	108	0.00	0	299	0	8
2	109	0.00	0	304	0	10
3	107	0.00	0	304	0	14
Average:					0	11
Rounded Average Flame Spread Rating (FSR):					0	-
Rounded Average Smoke Developed Classification (SDC):					-	10

### 7.1 Observations of Burning Characteristics

The specimens ignited approximately 107 to 109 seconds after exposure to the test flame. The flame fronts did not propagate past the base line.

## 8.0 RESULTS INTERPRETATION

CAN/ULC-S102 contains no performance criteria of its own. The National Building Code of Canada (NBCC) or other jurisdictional documentation should be referenced to determine the FSR and/or SDC performance criteria that is applicable to the material, for the intended application.



Francis Williams,  
Technician.



Ian Smith,  
Technical Manager.

### 8.1 Statement on Measurement Uncertainty (MU)

In CAN/ULC-S102, individual test data is reported in the form of indices (Flame Spread Value, Smoke Developed Value). As such, measurement uncertainty (MU) cannot be calculated.

*Note: This report and service are covered under Element Materials Technology Canada Inc. Standard Terms and Conditions of Contract which may be found on our company's website at [www.element.com](http://www.element.com), or by calling 1-866-263-9268.*

**9.0 TEST CHARTS**

**Test #1: "Snaile Locker Metal Cabinet"**

Chart 1. FLAME SPREAD (Specimen #1)




Chart 2. SMOKE DEVELOPED (Specimen #1)





Chart 3. TEMPERATURE (Specimen #1)




Flame Spread Value (FSV)	Smoke Developed Value (SDV)	Maximum Air Temperature (°C)
0	8	299


**9.0 TEST CHARTS (continued)**

**Test #2: "Snaile Locker Metal Cabinet"**


**Chart 4. FLAME SPREAD (Specimen #2)**



**Chart 5. SMOKE DEVELOPED (Specimen #2)**



**Chart 6. TEMPERATURE (Specimen #2)**



Flame Spread Value (FSV)	Smoke Developed Value (SDV)	Maximum Air Temperature (°C)
0	10	304

9.0 TEST CHARTS (continued)

Test #3: "Snaile Locker Metal Cabinet"

Chart 7. FLAME SPREAD (Specimen #3)




Chart 8. SMOKE DEVELOPED (Specimen #3)





Chart 9. TEMPERATURE (Specimen #3)



Flame Spread Value (FSV)	Smoke Developed Value (SDV)	Maximum Air Temperature (°C)
0	14	304